

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0495:116

Page 1 of 1

CATEGORY: Control Units (Non High-Rise)

LISTEE: Fire Burglary Instruments, Inc. *165 Eileen Way, Syosset, NY 11791
Contact: *David Kalmus (516) 921-6704

DESIGN: Models 7125F, XL4C, and XL5C control units. Coded or non-coded; local or central station (protected premises) service; waterflow and sprinkler supervisory service; manual or automatic. Refer to listee's data sheet for detailed product description and operation considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a fire alarm control unit when used in conjunction with System Sensor Model 2412 or 2412TH smoke detectors (CSFM Listing No. 7272-1209:103 and sound devices (bells) Ademco WFP10-12 (CSFM Listing No. 7135-0078:107) or System Sensor MA-12D audible signal device (CSFM Listing No. 7135-1209:124).

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

NOTE: Burglary and other non-fire functions were not examined.

*Rev. 06-10-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 11, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager